No Perakuan : JBPM.IP.RNP:700-7/2/1/3-1198
(BAHARU)

Jabatan Bomba dan Penyelamat Malaysia

SIJIL PEPASANGAN KESELAMATAN KEBAKARAN

Pintu Api / Fire Door
MS 1073: Part 3 Method for Determination of the Fire Resistance (Type of Doorsets)

Dengan ini diperakui
STANFORD-DOR MARKETING (M) SDN BHD
(CASPER)

Beroperasi di

42600 JENJAROM, SELANGOR

TELAH BERDAFTAR
TEMPOH SAH PERAKUAN : **31/10/2025 HINGGA 30/10/2027**

t.t

.....
Ketua Pengarah
Jabatan Bomba dan Penyelamat Malaysia

**Peringatan:
Sila patuhi sepenuhnya syarat-syarat dan had kegunaan seperti dalam Lampiran A1

(Sijil ini adalah cetakan berkomputer dan tidak memerlukan tandatangan)

LAMPIRAN A1

No. Fail: **JBPM.IP.RNP:700-7/2/1/3-1198**
No. Siri: **2025/S83/335/**

Jenis Alat Kelengkapan	:	**PINTU API / FIRE DOOR**
Jenama & Spesifikasi	:	**Brand: OCTOPUS** **Model: CASPER** **Type: DOUBLE LEAF METAL FRAME** **Tahap Ketahanan Api: 1 JAM** **Door Leaf: 2350mm x 2210mm x 48mm** **Door Frame: 2400mm x 2295mm x 140mm** **Type of Frame: METAL** **Door Core:** • **Type of Material: EPS Cement Solid Core Board** • **Density: 552 kg/m^3** • **Thickness: 42 mm** • **Others:** **Framework:** • **Type of Material: Finger Joint Timber** • **Density: 872 kg/m^3** • **Thickness: 42 mm** • **Others:** **Ironmongeries / Hardwares:** • **Brand of Door Closer: KEYSON 72V** • **Brand of Mortise Lockset (Lockcase / Cylinder / Lever): KEYSON 7255** • **Brand of Hinges: KEYSON** • **Brand of Eye Viewer:** **Vision Panel Size: 325mm x 170mm**
Tahap Rintangan Api	:	**Integriti: 65 min** **Insulasi: 65 min**
Nama & Alamat Pengeluar	:	**STANFORD-DOR MARKETING (M) SDN BHD**
No. Laporan Ujian/Tarikh	:	**2017FE0368 29/11/2017**
Jenis Skim Pensijilan Barangan	:	**SIRIM Product Certification (SIRIM QAS)**
No. Skim Pensijilan Barangan	:	**PC0003962**

Tempoh Sah Laku	: **02/11/2026**
Ulasan Pegawai Proses	: **PRA 1 JAM**
Ulasan Mesyuarat	: **LULUS PRA 1 JAM**
Had Kegunaan	: **PEMASANGAN HENDAKLAH MEMATUHI SPESIFIKASI SEPERTIMANA DALAM LAPORAN UJIAN DAN UBBL 1984 SERTA PERLU MEMATUHI SYARAT-SYARAT TAMBAHAN SEPERTI DI LAMPIRAN A2 & A3.**

Tempoh sah perakuan : **31/10/2025 hingga 30/10/2027**