No Perakuan : JBPM.IP.RNP:700-7/2/1/3-1183
(BAHARU)

Jabatan Bomba dan Penyelamat Malaysia

SIJIL PEPASANGAN KESELAMATAN KEBAKARAN

Pintu Api / Fire Door
MS 1073: Part 3 Method for Determination of the Fire Resistance (Type of Doorsets)

Dengan ini diperakui
STANFORD-DOR MARKETING (M) SDN BHD
(CASPER)

Beroperasi di
LOT 704, BATU 13, KG. SUNGAI RAMBAI, KUALA LANGAT
42600 JENJAROM, SELANGOR

TELAH BERDAFTAR
TEMPOH SAH PERAKUAN : **30/10/2025 HINGGA 29/10/2027**

t.t

.....
Ketua Pengarah
Jabatan Bomba dan Penyelamat Malaysia

**Peringatan:
Sila patuhi sepenuhnya syarat-syarat dan had kegunaan seperti dalam Lampiran A1

(Sijil ini adalah cetakan berkomputer dan tidak memerlukan tandatangan)

LAMPIRAN A1

No. Fail: **JBPM.IP.RNP:700-7/2/1/3-1183**
No. Siri: **2025/S83/332/**

Jenis Alat Kelengkapan	:	**PINTU API / FIRE DOOR**
Jenama & Spesifikasi	:	**Brand: OCTOPUS** **Model: CASPER** **Type: SINGLE LEAF METAL FRAME** **Tahap Ketahanan Api: 1 JAM** **Door Leaf: 2348mm x 1100mm x 48mm** **Door Frame: 2398mm x 1189mm x 140mm** **Type of Frame: METAL** **Door Core:** • **Type of Material: 'OCTO' EPS Cement FireBoard** • **Density: 584 kg/m^3** • **Thickness: 42 mm** • **Others:** **Framework:** • **Type of Material: Finger Joint Timber** • **Density: 812 kg/m^3** • **Thickness: 42 mm** • **Others:** **Ironmongeries / Hardwares:** • **Brand of Door Closer: KEYSON 72V, K-LINE 1304** • **Brand of Mortise Lockset (Lockcase / Cylinder / Lever): KEYSON 7255, KEYSON E8, YALE YDM3109, YALE YDM4109A, HAFELE DL7300, HBS H602, FIVE SENSES LS-5000, EMBLOC LS-5000, TESA/I-MAX, BE-TECH G536FK, K-LINE SLW001, ADEL 1800** • **Brand of Hinges: KEYSON** • **Brand of Eye Viewer: KEYSON DA-9308** **Vision Panel Size: 325mm x 170mm**
Tahap Rintangan Api	:	**Integriti: 65 min** **Insulasi: 65 min**
Nama & Alamat Pengeluar	:	**STANFORD-DOR MARKETING (M) SDN BHD**

No. Laporan Ujian/Tarikh	:	**2025FE0478-S1 19/06/2025, 2025FE0529 27/05/2025, 2025FE0477 20/05/2025, 2025FE0478 20/05/2025, 2024FE0212 29/04/2024, 2024FE0213 29/04/2024, 2023FE0386 18/07/2023, 2022FE0620 31/10/2022, 2022FE0129-S1 29/06/2022, 2022FE0111-S1 29/06/2022, 2022FE0129 04/03/2022, 2022FE0111 28/02/2022, 2019FE0650 08/11/2019, 2019FE0397 08/07/2019, 2017FE0389 31/07/2017**
Jenis Skim Pensijilan Barangan	:	**SIRIM Product Certification (SIRIM QAS)**
No. Skim Pensijilan Barangan	:	**PC003973**
Tempoh Sah Laku	:	**02/11/2026**
Ulasan Pegawai Proses	:	**PRA 1 JAM**
Ulasan Mesyuarat	:	**LULUS PRA 1 JAM**
Had Kegunaan	:	**PEMASANGAN HENDAKLAH MEMATUHI SPESIFIKASI SEPERTIMANA DALAM LAPORAN UJIAN DAN UBBL 1984 SERTA PERLU MEMATUHI SYARAT-SYARAT TAMBAHAN SEPERTI DI LAMPIRAN A2 & A3.**

Tempoh sah perakuan : **30/10/2025 hingga 29/10/2027**